

Bidhan Chandra Krishi Viswavidyalaya

WORKS DEPARTMENT, MOHANPUR, NADIA

Tender Notice No E / 02 / 2024 – '25 / 204

Dated : 23.07.2024

NOTICE INVITING TENDER

Sealed quotations are hereby invited from bonafide tenderers for connection of the air conditioners (AC) and allied work in the D.R. Sarkar Hall of the Faculty of Agriculture Building under B.C.K.V., Mohanpur, Nadia.

The necessary descriptions are given below

Sl. No.	Description of Item	Quantity	Unit	Rate	Total Amount
(1)	(3)	(4)	(5)	(6)	(7)
1	Supplying and fixing 100 A, 415V, TPN SFU with sheet steel enclosure on angle iron frame on wall with nuts bolts etc incl. S & F 3 nos. DIN type HRC fuse as per rating (Make - L & T).	1.00	No.		
2	Supplying and fixing 50 sq. mm. 4 core compression type gland complete with brass gland, brass ring and rubber ring for dust and moisture-proof entry of XLPE/PVC armoured cables.	4.00	No.		
3	Finishing the end of 50 sq. mm. 4 core XLPE/PVC armoured cables by crimping method including supplying and fixing solderless socket (Dowels make), tapes, anticorrosive paste and jointing materials	4.00	Set		
4	Supplying and fixing 4 Way double door Horizontal TPN MCB Distribution board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish including Inter connection with suitable size of copper wire and neutral link and provision for earthing attachment (Make - Legrand)	1.00	No.		
5	Supplying and fixing 2 + 16 Way double-door SPN MCB Distribution Board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment (Make - Legrand)	1.00	No.		
6	Supplying & fixing 240/415 V MCB of Breaking capacity 10kA & C characteristics on din rail of existing DBs & nece connection (Make - Legrand)				
6.1	SPMCB - 6-32 A	28.00	No.		
6.2	DPMCB - 40 A	1.00	No.		
6.3	FPMCB - 100 A	1.00	No.		
7	Supply & Fixing 240 V, 25A Modular type socket, 25 A, Modular type starter (Brand approved by EIC) with 25A Modular switch type DP MCB (C-Curve) and 6 Module GI Modular type switch board with 6 Module top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	5.00	No.		
8	Supply & Fixing 240 V, 20A, plug socket with separate 20 A Piano key type switch (Brand approved by EIC) on sheet metal switch board embedded in wall incl. S & F 150x100x65mm MS (16SWG) switch board and bakelite/perspex top cover of 3mm thick by Brass screws after making housing for switch by cutting bakelite/perspex cover and making necessary connections as required	1.00	No.		

(1)	(3)	(4)	(5)	(6)	(7)
9	Supply & Fixing 240 V, 3 nos. 6A, & 1 no. 20A plug socket with separate 3 nos. 6 A & 1 no. 20A Piano key type switch, indicator & 20A switch type SP MCB (Brand approved by EIC) on sheet metal switch board embedded in wall incl. S & F 240x200x65mm MS (16SWG) switch board and bakelite/perspex top cover of 3mm thick by Brass screws after making housing for switch by cutting bakelite/perspex cover and making necessary connections as required	2.00	No.		
10	Distribution wiring in 1.1 KV grade 2x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in suitable size PVC casing-capping (Precision make) with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, incl. necy. fittings etc. to light/fan/call bell point with Modular type switch (Brand approved by EIC) fixed on Modular GI switch board with top cover plate flushed in wall incl. mending good damages to original finish [PVC casing capping on surface and Switch board concealed] Average run 12 mtr	8.00	Point		
11	Supplying & Fixing sheet metal inspection box (16 SWG) of the following sizes flushed in wall by housing the same after cutting brick wall incl. making earthing attachment, painting and mending good damages to building works 240 mm x 200 mm x 65 mm	1.00	No.		
12	Supply & Fixing 240 V, 4 nos. 6A, plug socket with separate 4 nos. 6 A Piano key type switch, indicator & 16A MCB (Brand approved by EIC) on sheet metal switch board embedded in wall incl. S & F 240x200x65mm MS (16SWG) switch board and bakelite/perspex top cover of 3mm thick by Brass screws after making housing for switch by cutting bakelite/perspex cover and making necessary connections as required	1.00	No.		
13	Supply & Fixing bakelite / perspex top cover on existing switch board by Brass screws after making housing for switch by cutting bakelite / perspex cover and making necessary connections as required 240 mm x 200 mm x 65 mm	1.00	No.		
14	Wiring in 1.1 KV grade single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) of following sizes in 25mm PVC casing-capping (Precision make) incl. necy. PVC clips, fittings etc.				
14.1	2 x 22/0.3 (1.5 sqmm) + 1 x 22/0.3 (1.5 sqmm)	40.00	mtr.		
14.2	2 x 36/0.3 (2.5 sqmm) + 1 x 22/0.3 (1.5 sqmm)	80.00	mtr.		
14.3	2 x 56/0.3 (4 sqmm) + 1 x 36/0.3 (2.5 sqmm)	150.00	mtr.		
15	Supply & Fixing 240 V 20 A Piano key type switch (Brand approved by EIC) on existing sheet metal switch board having bakelite/perspex top cover by screws after making housing for switch by cutting bakelite/perspex cover and making necessary connections as required	5.00	No.		
		Total Rs.			
		Add GST @ 18% of 'A' Rs.			
		Rs.			
		Add Labour cess @ 1% of 'B' Rs.			
		Gross Total Rs.			
		Say Rs.			

Last date & time limit for receipt of sealed quotation at the said office on 31.07.2024 up to 2.00 P.M.

All eligible and willing tenderers are required to submit their quoted rate in company letter head as per above format along with valid GST Registration, P/Tax Challan, IT Return, PAN Card etc. & drop in tender box kept at Works Department within due date.


The rates quoted in the tender shall remain open for acceptance for 6(six) months from the date of tender.

The tendering authority does not bind himself to accept the lowest bidder and reserved the right to reject in part or in full or all the tender received or to split up the work in different groups without assigning any reasons thereof.

The tenders which do not fulfil any of the above conditions or are incomplete in any respect liable to summarily rejection.

If the successful tenderer fails to commence the work within 7 (seven) days from the date of receipt of work order without showing any valid reason, the work order will be treated as cancelled.

No departmental materials will be issued to the contractor and materials, tools and plants are to be supplied by the contractor.


23/7/24
In-Charge

Works Department
Bidhan Chandra Krishi Viswa Vidyalaya
Mohanpur, Nadia

No. WD / BCKV / EW – 03 / 2024-'25 / 204 / 1 (14) / 2024 Dated : 23.07.2024

Copy forwarded with a request to display in the notice board for wide circulation to:-

1. The Vice-Chancellor, B.C.K.V, Mohanpur, Nadia.
2. The Registrar (Officiating), B.C.K.V, Mohanpur, Nadia.
3. The Comptroller, B.C.K.V, Mohanpur, Nadia.
4. The Librarian, B.C.K.V, Mohanpur, Nadia with request to upload the tender notice in BCKV Website – www.bckv.edu.in.
5. The Director of Research, B.C.K.V., Kalyani, Nadia.
6. The Director of Farms, B.C.K.V., Mohanpur, Nadia.
7. The Director of Extension Education, B.C.K.V., Mohanpur, Nadia.
8. The Special Officer (Development), B.C.K.V., Kalyani, Nadia.
9. The Dean, Students' Welfare, B.C.K.V., Mohanpur, Nadia.
10. The Dean, Faculty of Agriculture, B.C.K.V., Mohanpur, Nadia.
11. The Dean, Faculty of Horticulture, B.C.K.V., Mohanpur, Nadia.
12. The Dean, Faculty of Agril. Engineering, B.C.K.V, Mohanpur, Nadia.
13. The SAE (Electrical), Works Department, B.C.K.V., Mohanpur, Nadia.
14. BCKV Website – www.bckv.edu.in


23/7/24
In-Charge

Works Department
Bidhan Chandra Krishi Viswa Vidyalaya
Mohanpur, Nadia